

**Tender A-44**

Phone No. 254295, Fax.No. 254066,(STD 02487

E-mail – kukadisugar@rediffmail.com

**Karmyogi Kundalikrao Ramrao Jagtap Patil Kukadi Sahakari Sakhar Karkhana Ltd.,**

P.O. Pimpalgaon Pisa, Tal : Shrigonda , Dist : Ahmednagar

Ref No.: KKRJPKSSK/Pur/ /2021-22

Date: / /2021

M/s \_\_\_\_\_

Sir,

It is our intention to procure the following materials / contract out our factory work and we are inviting quotations for the same. For that send your quotation in sealed cover pocket to our factory address. The last date for sending will be Date / / 2021. Request No. of the concerned department.....

Sr. No	Name of the articles with Specification	Required No. or Quantity	Rate Quoted	
			Exclusive Duty & Taxes	Inclusive Duty & Taxes
	<b>Supply of boiler PRDS station:</b>	<b>01 Job</b>		
	<p>Design, modify, manufacturing, supply, erection and commissioning of PRD station to our existing 87 to 1.5 kg/cm2 PRD station in to <b>87 to 45 kg/cm2</b> pressure reducing and DE superheating station require.</p> <p>You should provide steam pressure DE super heating station suitable pneumatic control valve. Make-KSB. They will give steam 87 to 45 kg/cm2 pressure and steam flow capacity 80 ton /hr. <b>The PRDSH stations will complete with high pressure piping</b>, valves, instrument and controls. The control of the PRDSH stations will be from existing plant DCS. Fully assembled valves/piping system will be hydrostatically shell tested by inspectorial authority which is in your scope of supply. In case IBR Approval, fully assembled valves/piping system shall be hydrostatically shell tested by you in unpainted condition during IBR inspection.</p> <p><b>Scope of supply:</b>            Outlet isolation valve- 8" = 01 no., Bypass valve 4" = 01 no.,            Globe valve for instruments/Drain- inlet 1/2" = 03 nos.,            Globe valve for instruments/Drain- outlet 1/2" = 03 nos.,            Inlet Pressure gauges with syphon - 6" 0 to 140 bar = 01 no.,            Outlet Pressure gauges with syphon - 6" 0 to 140 bar = 01 no.,            Inlet Dial thermometer - 6" 0 to 800 oC = 01 no.,            Outlet Dial thermometer - 6" 0 to 800 oC = 01 no.,            Pressure reducing valve- 6" WC9 body,SS431 nitrite internals, =01 no.,            Safety valve 4"X6" make- Tyco sunmar,            Pressure transmitter- 0- 140 bar, abb- make, Temperature transmitter 0-800 oC,</p>			

**Please note the following instructions:-**

- 1) Whether you are manufacturer / Registered dealer / Suppler, If Mfg / RD / Supplier. please quote your registration No .....
- 2) If you are supplier, then whether you are in position to submit 'S' Invoice.
- 3) Please quote correct Central Excise Chapter Heading of the capital goods/ chemicals which you are going to supply.
- 4) If the Central Excise Chapter heading of the capital goods is not mentioned in quotation form you will not be called for negotiation please note.
- 5) Quotations received after the date mentioned above will not be considered.
- 6) The rates quoted by you will be considered to be in force for 30 days from the date of receipt.
- 7) The word QUOTATION and above enquiry No Should be invariable written on the envelop.
- 8) Credit facilities should be mentioned please mention the % of discount that you would allow.
- 9) The delivery period should be correctly mentioned, whether from ready stock or from incoming consignment within the period of. By fax No 02487 – 254066.
- 10) The destination place of the delivery of goods should be clearly mentioned.

Yours Faithfully

**Managing Director**  
 KKRJP KUKADI SSK Ltd.